



- GENERAL NOTES**
- A. LOCATIONS OF EXISTING PANELS ARE APPROXIMATE. FIELD VERIFY PRIOR TO BIDDING AND BEFORE THE START OF CONSTRUCTION.
 - B. ELECTRICAL PANEL 2 SHALL BE COMPLETELY REPLACED. SEE PANEL SCHEDULE.
 - C. STAKE THE LOCATIONS OF EACH POLE FOR APPROVAL PRIOR TO DRILLING PIERS.
 - D. COORDINATE WITH UTILITY COMPANY FOR THE REMOVAL OF ONE UTILITY AREA LIGHT.
 - E. SPECIAL CARE SHALL BE TAKEN WHEN WORKING ON OR AROUND THE TENNIS/BASKETBALL COURT. COORDINATE WITH THE MANUFACTURER OF THE SPORT COURT SURFACE. MINIMIZE THE REMOVAL OF THE SPORT COURT SURFACE TO THE AREA IMMEDIATELY UNDER THE LIGHTING FIXTURE POLE LOCATION. REPLACE THE SPORT COURT SURFACE AS REQUIRED TO ASSURE NO WATER OR OTHER MATERIALS WILL PENETRATE THE AREA BETWEEN THE CONCRETE SURFACE AND THE SPORT COURT MATERIAL. INSTALL NEW SPORT COURT MATERIAL PER MANUFACTURERS INSTRUCTIONS.
 - F. ALTERNATE LIGHTING FIXTURES BBA AT THE BASKETBALL COURT SHALL BE PROVIDED WITH A CONCRETE SUPPORT 42" ABOVE GRADE. ALL OTHER CONCRETE SUPPORTS SHALL BE 12" ABOVE GRADE.
 - G. ALL NEW LIGHTING CIRCUITS SHALL BE EXTENDED FROM PANEL 2.

- NUMBERED NOTES**
1. THE CONTRACTOR SHALL REMOVE THE EXISTING LIGHTING FIXTURE AND POLE FROM THIS LOCATION. REMOVE THE EXISTING LIGHT FROM THE POLE AND PROVIDE APPROPRIATELY DRILLED HOLES FOR THE INSTALLATION OF A NEW LIGHTING FIXTURE TO THE POLE. INSTALL ONE FIXTURE EQUAL TO KENALL #TPD23-4HSS-TP-DB-160L50K-DV TO THE EXISTING POLE AND REINSTALL THE POLE TO THE EXISTING BASE SUPPORT. CONNECT THE FIXTURE TO THE EXISTING CIRCUIT.
 2. THE EXISTING BASKETBALL AND TENNIS COURT SURFACE SHALL BE PROTECTED THROUGHOUT THE CONSTRUCTION PROCESS. ONE LIGHTING POLE WILL BE INSTALLED THROUGH THE PLAYING SURFACE. SPECIAL CARE SHALL BE PROVIDED WHEN PREPARING THE SURFACE FOR CORING THROUGH THE SLAB TO MAKE SPACE FOR THE LIGHTING POLES' DRILLED PIER.
 3. NEW LIGHTING POLES (ALTERNATE) LOCATED WITH APPROXIMATELY 24" OF SPACE BETWEEN THE CONCRETE SUPPORT FOR THE POLE AND THE EXISTING RETAINING WALL (ALTERNATE) REMOVE THE EXISTING OVERHEAD CONDUCTORS AND UTILITY AREA LIGHT.
 4. EXISTING PAVILION. PROVIDE NEW LIGHTING AND OUTLETS IN THE PAVILION. REFER TO SHEET E3.03.
 5. MOUNT THESE LIGHTING FIXTURES ON A 42" STRUCTURAL SUPPORT. SEE DETAIL SHEET S1.00.
 6. PROVIDE TWO DEDICATED TIME CLOCKS MOUNTED NEXT TO PANEL 2 FOR CONTROL OF (1) THE SPORT COURT LIGHTING AND (2) THE TRAIL/VOLLEYBALL/PLAYSCAPE LIGHTING.

01 SITE PLAN

SCALE: 1" = 60'

<p>Project No. ABC-2008-01</p> <p>Sheet No. 01</p> <p>Project Name BCMUD PARK</p> <p>Site Plan/Lighting</p> <p style="text-align: right;">E3.01</p>	<p>HALFF</p> <p>TEXAS REGISTERED ENGINEERING FIRM #112</p> <p>TWO SIERRA WAY, SUITE 105 GEORGETOWN, TEXAS 75326-7571 TEL (512) 363-5632 FAX (512) 363-5639</p>	<p>HALFF ASSOCIATES, INC. ENGINEERS - SURVEYORS - SCIENTISTS PRELIMINARY - FOR INTERIM REVIEW ONLY</p> <p>These documents are the property of HALFF ASSOCIATES, INC. and are intended for the use of the client only. They are not to be distributed, copied, or reproduced in any form without the written consent of HALFF ASSOCIATES, INC.</p> <p>Project: BCMUD PARK Date: 03/2014</p>	<p>BCMUD PARK IMPROVEMENTS</p> <p>BRUSHY CREEK MUD 16318 GREAT OAKS DR. ROUND ROCK, TX 78681</p> <p style="text-align: right; font-size: x-small;">Supp 01 #108</p>
---	---	--	--