



- NUMBERED NOTES:**
1. EXISTING PANEL, PR TO BE REPLACED. SEE PANEL SCHEDULE.
  2. PROVIDE LIGHTING AND POWER DEVICES IN EXISTING RESTROOM BUILDING. REFER TO SHEET E1.02.
  3. EXISTING LIGHTING POLE WITH TWO FLOOD LIGHTS. REPLACE THE EXISTING LIGHTING FIXTURES WITH NEW LED FLOOD LIGHTING FIXTURES, TYPE FLB (ALTERNATE).
  4. PROVIDE PROPER MATERIALS TO COVER THE BASKETBALL COURT DURING CONSTRUCTION. DO NOT DRIVE MACHINERY ON TOP OF COURT WITHOUT PROOF THAT MATERIALS USED WILL PROTECT THE COURT.
  5. PROVIDE A SINGLE TRENCH FOR ALL CONDUIT SYSTEMS EXTENDING BACK TO PANEL, PR. ROUTE CONDUITS TO MINIMIZE THE IMPACT TO THE EXISTING TREES AND OTHER VEGETATION.
  6. PROVIDE NEW LIGHTING AND OUTLETS IN THE PAVILION. REFER TO SHEET E1.02.
  7. REFER TO SHEET E1.04 FOR THE ELECTRICAL RISER AND NEW PANEL SCHEDULE.

**01** SITE PLAN  
SCALE: 1" = 40'

|              |                  |
|--------------|------------------|
| DATE         | NOV 17 2014      |
| BY           | PHILIP APPELBAUM |
| CHECKED BY   | PHILIP APPELBAUM |
| SCALE        | 1" = 40'         |
| PROJECT      | BRUSHY CREEK MUD |
| SHEET NO.    | E1.01            |
| TOTAL SHEETS | 1                |
| DESIGNED BY  | PHILIP APPELBAUM |
| DRAWN BY     | PHILIP APPELBAUM |
| CHECKED BY   | PHILIP APPELBAUM |
| DATE         | NOV 17 2014      |

**HALFF**  
TEXAS REGISTERED  
ENGINEERING FIRM # 312

TWO SIERRA WAY, SUITE 105  
GEORGETOWN, TEXAS 78626-7574  
TEL (512) 863-4212  
FAX (512) 869-0089

HALFF ASSOCIATES, INC.  
ENGINEERS - SURVEYORS - SCIENTISTS  
PRELIMINARY - FOR INTERIM REVIEW ONLY

These documents are the Intellectual Property and are intended for Regulatory Approval, Permit, Bidding, or Construction Approval. They were prepared by or under the supervision of:

Philip Appelbaum 06504 7/03/2014  
Type or Print Name Title Date

**BCMUD PARK IMPROVEMENTS**  
BRUSHY CREEK MUD  
16318 GREAT OAKS DR.  
ROUND ROCK, TX 78681